



Standard Classification for Serviceability of an Office Facility for Special Facilities and Technologies^{1,2}

This standard is issued under the fixed designation E 1694; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This classification contains pairs of scales for classifying an aspect of the serviceability of an office facility, that is, the capability of an office facility to meet certain possible requirements for special facilities and technologies.

1.2 Each pair of scales shown in Figs. 1-6 printed side-by-side on a page, are for classifying one topic of serviceability within that aspect of serviceability. Each paragraph in an Occupant Requirement Scale (see Figs. 1-6) summarizes one level of serviceability on that topic that occupants might require. The matching entry in the Facility Rating Scale (See Figs. 1-6) is a translation of the requirement into a description of certain features of a facility that, taken in combination, indicate that the facility is likely to meet that level of required serviceability.

1.3 The entries in the Facility Rating Scale (See Figs. 1-6) are indicative and not comprehensive. They are for quick scanning, to estimate approximately, quickly, and economically, how well an office facility is likely to meet the needs of one or another type of occupant group over time. The entries are not for measuring, knowing, and evaluating how an office facility is performing.

1.4 This classification can be used to estimate the level of serviceability of an existing facility. It can also be used to estimate the serviceability of a facility that has been planned but not yet built, such as one for which single-line drawings and outline specifications have been prepared.

1.5 This classification indicates what would cause a facility to be rated at a certain level of serviceability, but it does not state how to conduct a serviceability rating nor how to assign a serviceability score. That information is found in Practice E 1334. The scales in this classification are complementary to and compatible with Practice E 1334. Each requires the other.

¹ This classification is under the jurisdiction of ASTM Committee E-6 on Performance of Buildings and is the direct responsibility of Subcommittee E06.25 on Whole Buildings and Facilities.

Current edition approved March 15 and April 15, 1995. Published August 1995.

² Portions of this document are based on material originally prepared by the International Centre for Facilities (ICF) and © 1993 by ICF and Minister of Public Works and Government Services Canada. Their cooperation in the development of this standard is acknowledged.

2. Referenced Documents

2.1 ASTM Standards:

E 631 Terminology of Building Constructions³

E 1334 Practice for Rating Serviceability of a Building or Building-Related Facility³

E 1679 Practice for Setting Requirements for Serviceability of a Building or Building-Related Facility³

2.2 ISO Documents:⁴

ISO 6240 International Standard, Performance Standards in Building—Contents and Presentation

ISO/DIS 7162 Draft International Standard, Performance Standards in Building—Contents and Format of Standards for Evaluation of Performance

ISO/DIS 7164 Draft International Standard, Performance Standards in Building—Definitions and Means of Expression for the Performance of a Whole Building

3. Terminology

3.1 *Definitions*—For standard definitions of terms applicable to this classification, see Terminology E 631.

3.1.1 *facility, n*—a physical setting used to serve a specific purpose.

3.1.1.1 *Discussion*—A facility may be within a building, or a whole building, or a building with its sites and surrounding environment; or it may be a construction that is not a building. The term encompasses both the physical object and its use.

(E 631)

3.1.2 *facility serviceability*—the capability of a facility to perform the function(s) for which it is designed, used, or required to be used.

3.1.2.1 *Discussion*—The scope of this performance is of the facility as a system, including its subsystems, components, and materials and their interactions, such as acoustical, hydrothermal, air purity, and economic; and of the relative importance of each performance requirement.

(E 631)

³ *Annual Book of ASTM Standards*, Vol 04.11.

⁴ Available from American National Standards Institute, 11 W. 42nd St., 13th Floor, New York, NY 10036.

A.13. Special Facilities and Technologies

Scale A.13.1. Group or shared conference centre

Occupant Requirement Scale	Facility Rating Scale
<p>9 <input type="checkbox"/> LOCATION OF MEETING <input type="checkbox"/> SPACE: Require consistent access to a conference centre for the organization in the same building or complex. <input type="checkbox"/> SIZE OF MEETINGS: For large meetings, e.g. 50 to 100 people.</p>	<p>9 <input type="checkbox"/> Present provision: A departmental conference centre exists, able to handle several groups of 25 to 50 people at tables in adjacent meeting rooms, with a main plenary session of 200 people or more.</p>
<p>7 <input type="checkbox"/> LOCATION OF MEETING <input type="checkbox"/> SPACE: Can tolerate using space in a canteen, work area or display area. <input type="checkbox"/> SIZE OF MEETINGS: Require space for large meetings in the same building, e.g. 100 people. <input type="checkbox"/> FUTURE NEED FOR A CONFERENCE CENTRE: A certain or very likely need in the future for a departmental conference centre in the same building or complex.</p>	<p>7 <input type="checkbox"/> Present provision: A departmental conference centre is not provided. Large meetings, e.g. 100 people, can take place in a separate display or work area where office work is only minimally disrupted, or, in a portion of a food service eating area that can easily be closed off. <input type="checkbox"/> Potential space: There is space available for a dedicated departmental conference centre, with the necessary qualities of size, dimensions, location, and access to facilities. <input type="checkbox"/> Potential services: Building services could be modified or added to, at reasonable effort and cost.</p>
<p>5 <input type="checkbox"/> LOCATION OF MEETING <input type="checkbox"/> SPACE: Can tolerate using space in an open plan area adjacent to a main circulation route or lobby. <input type="checkbox"/> SIZE OF MEETINGS: Require space for large meetings in the same building, e.g. 100 people. <input type="checkbox"/> FUTURE NEED FOR A CONFERENCE CENTRE: Foresee a possible need in the future for a departmental conference centre in the same building or complex.</p>	<p>5 <input type="checkbox"/> Present provision: A departmental conference centre is not provided. Large meetings, e.g. 100 people, can take place in an open plan area, located close to the main circulation route and entry. <input type="checkbox"/> Potential space: Space is available for a dedicated departmental conference centre, but is of marginal quality, e.g. marginal ceiling height for a main auditorium, poor location in the building, insufficient nearby toilets, and marginal space for adjacent meeting rooms. <input type="checkbox"/> Potential services: Building services are inadequate, but with sufficient capacity to upgrade, or could be added with moderate difficulty and cost.</p>
<p>3 <input type="checkbox"/> LOCATION OF MEETING <input type="checkbox"/> SPACE: No present or future need for a departmental conference facility in the same building or complex.</p>	<p>3 <input type="checkbox"/> Potential space: A departmental conference centre is not provided. There is no suitable space available, e.g. insufficient ceiling height for a main auditorium, and narrow room dimensions. Meeting rooms are not adjacent, and have poor access. <input type="checkbox"/> Potential services: Building services are inadequate. There is some capacity or space to upgrade but very difficult and costly.</p>
<p>1 <input type="checkbox"/> LOCATION OF MEETING <input type="checkbox"/> SPACE: There is no requirement at this level. <input type="checkbox"/> SIZE OF MEETINGS: There is no requirement at this level. <input type="checkbox"/> FUTURE NEED FOR A CONFERENCE CENTRE: There is no requirement at this level.</p>	<p>1 <input type="checkbox"/> Potential space: A departmental conference centre is not provided. There is no available space, e.g. insufficient space for adjacent meeting rooms and office, and insufficient public circulation space. <input type="checkbox"/> Potential services: Building services are inadequate with no capacity or space to upgrade. Sound separation is inadequate and upgrade is very difficult and costly.</p>

<input type="checkbox"/> Exceptionally important.	<input type="checkbox"/> Important.	<input type="checkbox"/> Minor Importance.
Minimum Threshold level =		
<input type="checkbox"/> NA	<input type="checkbox"/> NR	<input type="checkbox"/> Zero <input type="checkbox"/> DP

NOTES Space for handwritten notes on Requirements or Ratings

FIG. 1 Scale A.13.1 for Group or Shared Conference Center

A.13. Special Facilities and Technologies

Scale A.13.2. Video teleconference facilities

Occupant Requirement Scale	Facility Rating Scale
<p>9 <input type="checkbox"/> PRESENT NEED FOR FACILITY: Require immediate access to a video teleconference centre in the same building or complex.</p>	<p>9 <input type="checkbox"/> Present provision: A dedicated video teleconference centre is fully installed to a good standard, or is easily upgraded.</p>
<p>7 <input type="checkbox"/> PRESENT NEED FOR FACILITY: No immediate need for a teleconference centre in the same building or complex. FUTURE NEED FOR FACILITY: A certain or very likely need in the future for a video teleconference centre in the same building or complex.</p>	<p>7 <input type="checkbox"/> Potential space: Video teleconference facilities are not provided. Space for a video teleconference facility is good, e.g. in the range of 3.0 m to 3.5 m ceiling height in screen end of space. Potential services: Building services are easily capable of providing special conditions required with minimum effort and cost. Air handling is very quiet.</p>
<p>5 <input type="checkbox"/> PRESENT NEED FOR FACILITY: No immediate need for a video teleconference centre in the same building. FUTURE NEED FOR FACILITY: A possible need in the future for a video teleconference centre in the same building or complex.</p>	<p>5 <input type="checkbox"/> Potential space: Video teleconference facilities are not provided. Space for a video teleconference facility is just adequate, e.g. in the range of 3.0 m ceiling height. Potential services: There is capability in building services to provide the special conditions required, if upgraded, or special air handling and acoustic isolation can be added with moderate effort and cost.</p>
<p>3 <input type="checkbox"/> PRESENT NEED FOR FACILITY: No present need for a video teleconference centre in the same building or complex. FUTURE NEED FOR FACILITY: No future need for a video teleconference centre in the same building or complex.</p>	<p>3 <input type="checkbox"/> Potential space: Video teleconference facilities are not provided. There is no suitable space, e.g. marginal ceiling height, and poor location. Potential services: Building services are inadequate. There is some capacity to upgrade ventilation, but it is very difficult and costly. Sound separation is insufficient and upgrade is very difficult and costly.</p>
<p>1 <input type="checkbox"/> PRESENT NEED FOR FACILITY: No requirement at this level. FUTURE NEED FOR FACILITY: No requirement at this level.</p>	<p>1 <input type="checkbox"/> Potential space: Video teleconference facilities are not provided. There is no space, e.g. insufficient ceiling height. Potential services: Building services are inadequate with no capacity to upgrade. Sound separation is insufficient and upgrade is very difficult and costly.</p>

<input type="checkbox"/> Exceptionally important. <input type="checkbox"/> Important. <input type="checkbox"/> Minor Importance.	
Minimum Threshold level =	<input type="checkbox"/> NA <input type="checkbox"/> NR <input type="checkbox"/> Zero <input type="checkbox"/> DP

NOTES Space for handwritten notes on Requirements or Ratings

FIG. 2 Scale A.13.2 for Video Teleconference Facilities

A.13. Special Facilities and Technologies

Scale A.13.3. Simultaneous translation

Occupant Requirement Scale	Facility Rating Scale
<p><input type="checkbox"/> 9 ○ PRESENT NEED FOR TRANSLATION FACILITY: Operations require permanent translation facilities in at least one large conference or meeting room.</p>	<p><input type="checkbox"/> 9 ○ Present provision: Permanent translation facilities are provided in one or two of the largest conference and meeting rooms. Space is available in several meeting rooms for portable booths. Cables and electronic equipment are installed.</p>
8	8
<p><input type="checkbox"/> 7 ○ PRESENT NEED FOR TRANSLATION FACILITY: Occasional need for permanent translation facilities. Can tolerate using meeting rooms with portable booths for translators. ○ FUTURE NEED FOR FACILITY: A certain or very likely need in the future for permanent translation facilities in the building or complex.</p>	<p><input type="checkbox"/> 7 ○ Present provision: Permanent translation booths are provided in one or two of the largest conference and meeting rooms. Translators bring their own equipment and cabling. Some existing meeting rooms are suitable for portable booths for translators. ○ Potential for translator facilities: The building could easily be fitted up to provide permanent facilities to a high standard, at a low cost, e.g. flat cable under carpet tile, enhanced ventilation and good acoustics.</p>
6	6
<p><input type="checkbox"/> 5 ○ PRESENT NEED FOR TRANSLATION FACILITY: No present need for permanent translation facilities. Can tolerate using meeting rooms with portable booths for translators. ○ FUTURE NEED FOR FACILITY: A possible need in the future for permanent translation facilities in the building or complex.</p>	<p><input type="checkbox"/> 5 ○ Present provision: No permanent accommodation exists for simultaneous translation. Some existing meeting rooms are suitable for portable booths for translators. ○ Potential for translator facilities: The building could be fitted up to provide permanent facilities for translators at moderate cost and difficulty, and provide adequate quality, e.g. cables in combination with surface conduit and ceiling space, and booth ventilation the same as for meeting rooms.</p>
4	4
<p><input type="checkbox"/> 3 ○ PRESENT NEED FOR TRANSLATION FACILITY: No present need for permanent translation facilities. Can tolerate using meeting rooms with portable booths for translators. ○ FUTURE NEED FOR FACILITY: No foreseeable need for permanent translation facilities in the building or complex.</p>	<p><input type="checkbox"/> 3 ○ Present provision: No permanent accommodation exists for simultaneous translation. Some existing meeting rooms are marginally suitable for portable booths for translators. ○ Potential for translator facilities: The building could be fitted up to provide technical facilities for translators, but with marginal quality, e.g. surface run cables, ventilation the same as for open office, or, very costly and difficult.</p>
2	2
<p><input type="checkbox"/> 1 ○ PRESENT NEED FOR TRANSLATION FACILITY: No need for translation facilities now, or in the future.</p>	<p><input type="checkbox"/> 1 ○ Present provision: No permanent accommodation exists for simultaneous translation. If meeting rooms exist, they are not suitable for portable booths for translators. ○ Potential for translator facilities: No capability exists to provide technical facilities for translators, e.g. a booth with ventilation and cables.</p>
1	1

<input type="checkbox"/> Exceptionally important. <input type="checkbox"/> Important. <input type="checkbox"/> Minor Importance.	
Minimum Threshold level =	<input type="checkbox"/> NA <input type="checkbox"/> NR <input type="checkbox"/> Zero <input type="checkbox"/> DP

NOTES Space for handwritten notes on Requirements or Ratings

FIG. 3 Scale A.13.3 for Simultaneous Translation

A.13. Special Facilities and Technologies

Scale A.13.4. Satellite and microwave links

Occupant Requirement Scale	Facility Rating Scale
<p><input type="checkbox"/> 9 ○ PRESENT NEED FOR LINK: Require immediate use of a satellite or microwave link.</p> <p style="text-align: center;">8 <input type="checkbox"/></p> <p><input type="checkbox"/> 7 ○ PRESENT NEED FOR LINK: No immediate need for a satellite or microwave link. ○ FUTURE NEED FOR LINK: A certain or very likely need in the future for a satellite or microwave link.</p> <p style="text-align: center;">6 <input type="checkbox"/></p> <p><input type="checkbox"/> 5 ○ PRESENT NEED FOR LINK: No immediate need for a satellite or microwave link. ○ FUTURE NEED FOR LINK: Foresee a possible need in the future for a satellite or microwave link.</p> <p style="text-align: center;">4 <input type="checkbox"/></p> <p><input type="checkbox"/> 3 ○ PRESENT NEED FOR LINK: No immediate need for a satellite or microwave link. ○ FUTURE NEED FOR LINK: No foreseeable need for a satellite or microwave link.</p> <p style="text-align: center;">2 <input type="checkbox"/></p> <p><input type="checkbox"/> 1 ○ PRESENT NEED FOR LINK: No need for a satellite or microwave link. ○ FUTURE NEED FOR LINK: No need for a satellite or microwave link in the future.</p>	<p><input type="checkbox"/> 9 ○ Present provision: Satellite or microwave links are installed.</p> <p style="text-align: center;">8 <input type="checkbox"/></p> <p><input type="checkbox"/> 7 ○ Potential for installation: There are presently no satellite or microwave links. Satellite and microwave links are possible, with building preparation at low cost and effort, e.g. ground area has line-of-sight, or roof has structural strength for a large dish without additional strengthening.</p> <p style="text-align: center;">6 <input type="checkbox"/></p> <p><input type="checkbox"/> 5 ○ Potential for installation: There are presently no satellite or microwave links. Satellite and microwave links are possible, with building preparation at moderate cost and effort, e.g. roof has line-of-sight, and roof has structural strength for a large dish without major strengthening.</p> <p style="text-align: center;">4 <input type="checkbox"/></p> <p><input type="checkbox"/> 3 ○ Potential for installation: There are presently no satellite or microwave links. No provision for satellite and microwave links is possible without major cost and effort, e.g. roof lacks structural strength for a large dish without major strengthening. Line-of-sight is not available from ground level.</p> <p style="text-align: center;">2 <input type="checkbox"/></p> <p><input type="checkbox"/> 1 ○ Potential for installation: There are presently no satellite or microwave links. No provision exists for satellite and microwave links, e.g. line-of-sight is not available from ground or roof level. There is no structural capability for this on the roof.</p>

<input type="checkbox"/> Exceptionally important. <input type="checkbox"/> Important. <input type="checkbox"/> Minor Importance.	
Minimum Threshold level =	<input type="checkbox"/> NA <input type="checkbox"/> NR <input type="checkbox"/> Zero <input type="checkbox"/> DP

NOTES Space for handwritten notes on Requirements or Ratings

FIG. 4 Scale A.13.4 for Satellite and Microwave Links

3.1.3 *office*—a place, such as a room, suite, or building, in which business, clerical, or professional activities are conducted. (E 631)

4. Significance and Use

4.1 Each Facility Rating Scale in this classification provides a means for estimating the level of serviceability of a building or facility for one topic of serviceability, and for comparing that level against the level of any other building or facility.

4.2 This classification can be used for comparing how well different buildings or facilities meet a particular requirement for serviceability. It is applicable despite differences such as location, structure, mechanical systems, age, and building shape.

4.3 This classification can be used to estimate the amount of variance of serviceability from target or from requirement, for a single office facility, or within a group of office facilities.

A.13. Special Facilities and Technologies

Scale A.13.5. Mainframe computer centre

Occupant Requirement Scale	Facility Rating Scale
<p>9 <input type="checkbox"/> PRESENT NEED FOR COMPUTER CENTRE: Require immediate use of a mainframe computer centre of good quality, e.g. with access floor, full ceiling height, separate air handling with exhaust to the outside, and backup power.</p> <p style="text-align: right;">8 <input type="checkbox"/></p> <p>7 <input type="checkbox"/> PRESENT NEED FOR COMPUTER CENTRE: No immediate need for a mainframe centre. FUTURE NEED FOR COMPUTER CENTRE: A certain or very likely need in the future for a computer centre of good quality.</p> <p style="text-align: right;">6 <input type="checkbox"/></p> <p>5 <input type="checkbox"/> PRESENT NEED FOR COMPUTER CENTRE: No immediate need for a mainframe computer centre. FUTURE NEED FOR COMPUTER CENTRE: Foresee a possible need in the future for a computer centre.</p> <p style="text-align: right;">4 <input type="checkbox"/></p> <p>3 <input type="checkbox"/> PRESENT NEED FOR COMPUTER CENTRE: No immediate need for a mainframe computer centre. FUTURE NEED FOR COMPUTER CENTRE: No foreseeable need in the future for a computer centre.</p> <p style="text-align: right;">2 <input type="checkbox"/></p> <p>1 <input type="checkbox"/> PRESENT NEED FOR COMPUTER CENTRE: No need for a mainframe computer centre. FUTURE NEED FOR COMPUTER CENTRE: No need for a mainframe computer centre in the future.</p>	<p>9 <input type="checkbox"/> Present provision: A mainframe computer centre is already installed, with full access flooring, and a minimum 2.4 m height between access floor and ceiling. There is a separate air handling unit drawing outside air and exhausting to the outside. There is a backup power supply.</p> <p>7 <input type="checkbox"/> Present provision: No mainframe computer centre exists, but there are one or more small computer rooms. Potential for installation: It is possible to install a computer centre, with little difficulty and cost to upgrade the building, e.g. has suitable ceiling height and floor load capacity, can add to or upgrade raised floor, can add dedicated ventilation, has ceiling and light fixtures, power, mechanical systems, and a firefighting system.</p> <p>5 <input type="checkbox"/> Potential for installation: No mainframe computer centre exists. It is possible to install a computer centre, with moderate difficulty and cost to prepare the building, e.g. has suitable ceiling height and floor load capacity, can install a raised floor, can add dedicated ventilation, has ceiling and light fixtures, power, mechanical systems, and a firefighting system.</p> <p>3 <input type="checkbox"/> Potential for installation: No mainframe computer centre exists. It is possible to install a computer centre, but it is difficult and costly, e.g. need a major refit of part of the facility, with great difficulty and expense.</p> <p>1 <input type="checkbox"/> Potential for installation: No mainframe computer centre exists. It is not feasible to install a computer centre, e.g. need major reconstruction of part of the facility, due to inadequate ceiling height, ventilation, power supply, and floor load capacity.</p>

<input type="checkbox"/> Exceptionally important. <input type="checkbox"/> Important. <input type="checkbox"/> Minor Importance.	
Minimum Threshold level =	<input type="checkbox"/> NA <input type="checkbox"/> NR <input type="checkbox"/> Zero <input type="checkbox"/> DP

NOTES Space for handwritten notes on Requirements or Ratings

FIG. 5 Scale A.13.5 for Mainframe Computer Center

4.4 This classification can be used to estimate the following: (1) serviceability of an existing facility for uses other than its present use; (2) the serviceability (potential) of a facility that

has been planned but not yet built; and (3) the serviceability (potential) of a facility for which a remodelling has been planned.

A.13. Special Facilities and Technologies

Scale A.13.6. Telecommunications centre

Occupant Requirement Scale	Facility Rating Scale
<p><input type="checkbox"/> 9 ○ IMMEDIATE NEED FOR ACCESS TO A CENTRE: Require immediate use of a telecommunications centre of good quality, e.g. with backup and standby services and adequate physical security.</p>	<p><input type="checkbox"/> 9 ○ Present provision: A telecommunications centre is already installed, with full backup and standby services, e.g. data and phone lines are physically protected from the centre to the underground building entry, standby power, separate ventilation capability, backup water supply, satellite or microwave link, adequate physical security, and adequate floor load capacity and seismic design.</p>
<p><input type="checkbox"/> 7 ○ IMMEDIATE NEED FOR ACCESS TO A CENTRE: No immediate need for access to a telecommunications centre. ○ FUTURE NEED FOR ACCESS TO A CENTRE: A certain or very likely need in the future for a communications centre of good quality.</p>	<p><input type="checkbox"/> 7 ○ Present provision: An inadequate telecommunications centre exists. ○ Potential for installation: The building could be fitted up to provide a good quality telecommunications centre at moderate or low cost and difficulty, e.g. standby power, separate ventilation capability, backup water supply, secure phone lines, satellite or microwave link, adequate physical security, and adequate floor load capacity and seismic design.</p>
<p><input type="checkbox"/> 5 ○ IMMEDIATE NEED FOR ACCESS TO A CENTRE: No immediate need for access to a telecommunications centre. ○ FUTURE NEED FOR ACCESS TO A CENTRE: Foresee a possible need in the future for a communications centre.</p>	<p><input type="checkbox"/> 5 ○ Present provision: No telecommunications centre exists. ○ Potential for installation: The building could be fitted up to provide an adequate telecommunications centre at high cost and difficulty, e.g. standby power, separate ventilation capability, backup water supply, secure phone lines, satellite or microwave link, adequate physical security, and adequate floor load capacity and seismic design.</p>
<p><input type="checkbox"/> 3 ○ IMMEDIATE NEED FOR ACCESS TO A CENTRE: No immediate need for access to a telecommunications centre. ○ FUTURE NEED FOR ACCESS TO A CENTRE: No foreseeable need in the future for a communications centre.</p>	<p><input type="checkbox"/> 3 ○ Present provision: No telecommunications centre exists. ○ Potential for installation: It is possible, but extremely difficult and costly to prepare the building, e.g. it is difficult to provide standby power, ventilation, water, phone lines, adequate physical security, and adequate floor load capacity and seismic design.</p>
<p><input type="checkbox"/> 1 ○ IMMEDIATE NEED FOR ACCESS TO A CENTRE: No need for a telecommunications centre. ○ FUTURE NEED FOR ACCESS TO A CENTRE: No need for a telecommunications centre in the future.</p>	<p><input type="checkbox"/> 1 ○ Present provision: No telecommunications centre exists. ○ Potential for installation: It is not feasible or possible, e.g. it is impractical to provide standby power, ventilation, water, phone lines, adequate physical security, and adequate floor load capacity and seismic design.</p>

<input type="checkbox"/> Exceptionally important. <input type="checkbox"/> Important. <input type="checkbox"/> Minor Importance.	
Minimum Threshold level =	<input type="checkbox"/> NA <input type="checkbox"/> NR <input type="checkbox"/> Zero <input type="checkbox"/> DP

NOTES Space for handwritten notes on Requirements or Ratings

FIG. 6 Scale A.13.6 for Telecommunications Center

4.5 The use of this classification does not result in building evaluation or diagnosis. Building evaluation or diagnosis

generally requires special expertise in building engineering or technology and the use of instruments, tools, or measurements.

4.6 This classification applies only to facilities that are building constructions or parts thereof. (While this classification may be useful in rating the serviceability of facilities that are not building constructions, such facilities are outside the scope of this classification.)

4.7 This classification is not intended for, and is not suitable for, use for regulatory purposes, nor for fire hazard assessment nor for fire risk assessment.

5. Basis of Classification

5.1 The scales shown in Figs. 1-6 contain the basis for classification.

5.2 Instructions for the use of this classification are contained in Practices E 1334 and E 1679.

6. Keywords

6.1 building; computer center; mainframe; conference center; facility; facility occupants; function; microwave communication; office; performance; rating; rating scale; requirements; serviceability; simultaneous translation; telecommunications center; use; video teleconference

The American Society for Testing and Materials takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org).